

# CAVIUS


## MAINTENANCE SCHEDULE

**PRODUCT NAME:** CAVIUS 10 Year Photoelectric Smoke Alarm

**PRODUCT CODE:** CAV10

**PRODUCT CERTIFICATION:** AS3786, EN14604

**PRODUCT IMAGE:**



**LOW BATTERY INDICATOR:** A short acoustic “beep” will sound when the battery is near its end of life. In this stage it will continue for a maximum of 30 days. You must change the smoke alarm after 10 years usage, or if the smoke alarm has suffered any damage.

**ALL SMOKE ALARMS HAVE AN EXPIRY DATE, PLEASE CHECK ON THE BACK OF THE ALARM.**

**MAINTENANCE:** The smoke alarm should be vacuum cleaned once per month, and it can be wiped with a damp cloth (do not open the alarm). Test the smoke alarm once per month by pushing the test button. The smoke alarm should give a loud alarm tone.



For further information, please refer to the Instruction Manual, which can be found on [www.cavius.co.nz](http://www.cavius.co.nz)